


STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



OFFICE USE ONLY 109119

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 104 pg 1 of 2

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62647

1. OWNER Parks Dept, Carson City  
MAILING ADDRESS 3303 Butti Way, #9  
Carson City, NV 89701

ADDRESS AT WELL LOCATION 601 Old Clear Creek Rd  
Carson City, NV 89705  
Subdivision Name: Fuji Park Pond County: Carson City

2. LOCATION SE 1/4 SE 1/4 Sec 31 T 15N N/S R 20 E  
PERMIT/WAIVER No. DEW-80 1520-009-303-003  
Issued by Water Resources Parcel No.

Latitude 39 06'50.99" UTM E  NAD 27  
Longitude 119 46'27.30" N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. X Domestic  PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
See Attached				
well #9				
39.114255° N				
119.773236° W				
NAD 27 (TA)				
PLUGGED BY NOT #62642				
See Plugging LOG # 109407				
2009 NOV -6 PM 12:04				
STATE ENGINEER JEFFREY				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
40		40	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
24	0	40	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	40

Perforations:

Type of perforation machine slot  
Size of perforation 0.032

From	feet to	feet
20	40	

Annular Seal:  Yes  No

	to		
<input type="checkbox"/> Neat Cement		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	10 to 12	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured

Gravel Pack:  Yes  No 12 to 40  Pumped  Poured  
Type: 3/8 Pea Gravel

Bentonite Chips:  Yes  No 10 to 12  Pumped  Poured  
Type: 3/8's

7. Water Level  
Static water level: 7 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Viking Drillers Inc Contractor  
Address 801 Northport Dr. Contractor  
West Sacramento, CA  
Nevada contractor's license number issued by the State Contractor's Board 0034680  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2091  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 11/4/09

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER.

LOG # 109119 PA 20F2

LOG FOR BORING NO. (9)

JOB NAME: F & P Construction

DATE STARTED 9/29/09	DATE COMPLETED 9/29/09	LOGGED BY EB	DRILLED BY EB	TYPE OF DRILL RIG #32	JOB NO. 5967
DEPTH OF HOLE 40'	DIAMETER OF HOLE 24"	CASING 8"	PERFORATIONS 20'	SAMPLING METHOD	ELEVATION

LOCATION

DRILLERS NOTES:

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
0'			BROWN SILTY SAND MED TO FINE
10'		7	Gray SAND - MED BROWN SILTY CLAY SANDY CLAY
20'			Cemented SAND & cobbles/gravel
30'			Weathered bedrock with cobbles
40'			SILTY SAND
50'			
60'			
70'			
80'			
90'			
100'			

REVIEWED  
 2009 NOV -6 PM 12: 04  
 STATE ENGINEER'S OFFICE