


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY
Log No. 109/26
Permit No. 104 PS/02
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62647

1. OWNER Parks Dept, Carson City ADDRESS AT WELL LOCATION 601 Old Clear Creek Rd
MAILING ADDRESS 3303 Butti Way, #9 Carson City, NV 89705
Carson City, NV 89701 Subdivision Name: Fuji Park Pond County: Carson City

2. LOCATION SE 1/4 SE 1/4 Sec 31 T 15N N/S R 20 E Latitude 39°06'53.54" UTM E NAD 27
PERMIT/WAIVER No. DEW-80 1520-009-303-003 Longitude 119°46'24.86" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. 4x Domestic PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
See Attached				
<u>PLUGGED BY WELL # 62647</u>				
<u>Well #16</u>				
<u>See Plugging Log 109414</u>				
<u>39.114963° N</u>				
<u>119.742558° W</u>				
<u>NOV 23 10</u>				
<u>2009 NOV -6 PM 12:05</u>				
<u>STATE ENGINEERS OFFICE</u>				

Date started: 2-Oct, 2009
Date completed: 2-Oct, 2009

9. WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>24</u> Inches	<u>0</u> Feet <u>40</u> Feet
..... Inches Feet
..... Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>3/8</u>	<u>0</u>	<u>40</u>
.....
.....

Perforations:

Type of perforation machine slot
Size of perforation 0.032

From	to	feet to	feet
<u>20</u>	<u>40</u>	<u>40</u>	feet
.....	feet
.....	feet
.....	feet
.....	feet

Annular Seal: Yes No

<input type="checkbox"/> Neat Cement to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	<u>10</u> to <u>12</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>12</u> to <u>40</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>3/8 Pea Gravel</u>		
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>10</u> to <u>12</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	<u>3/8's</u>		

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.....
.....
.....
.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Viking Drillers Inc Contractor
Address 801 Northport Dr. Contractor
West Sacramento, CA

Nevada contractor's license number issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2091

Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11/4/09

LOG # 109126 on 2/2/09

LOG FOR BORING NO. (16) 17		JOB NAME: F. & P CONSTRUCTION			
DATE STARTED 10/2/09	DATE COMPLETED 10/2/09	LOGGED BY EB	DRILLED BY EB	TYPE OF DRILL RIG #32	JOB NO. 5987
DEPTH OF HOLE 70'	DIAMETER OF HOLE 24"	CASING 8"	PERFORATIONS 20'	SAMPLING METHOD	ELEVATION

LOCATION

DRILLERS NOTES:

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
			Brown silty sand
10'		▽	gray sand Tight MED
20'			sand of cobbles Tight
30'			Weathered bedrock Tight
40'			
50'			
60'			
70'			
80'			
90'			
100'			

REOPENED
 2009 NOV - 6 PM 12: 05
 STATE ENGINEERS OF ILL.