

REPORT NO. A9.36

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT



LOG NO. 109129
PERMIT NO. 148
BASIN 148

NOTICE OF INTENT NO. 63746

1. OWNER Campbell Construction

ADDRESS OF WELL Crystal Clean Water Co.

MAILING ADDRESS 36 Glen Carren Circle, Sparks, NV 89431

Yerington, NV

2. WELL LOCATION SWSE 1/4 SW 1/4 SEC. 3 T 13 R 26 E Lyon COUNTY

PERMIT NO. 31565 PARCEL NO. _____ SUBDIVISION NAME _____

3. TYPE OF WORK

New Well Replace Recondition
 Deepen Plug Other

4. PROPOSED USE

Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE

Cable Rotary RVC
 Air Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS				
Plugging well log # 18784								
39.014411°N								
119.064232°W NAD 27 (74)								
RECEIVED 2009 OCT 29 AM 11:29 STATE ENGINEERS OFFICE								

8. WELL CONSTRUCTION

Depth Drilled 300 Depth Cased 300

HOLE DIAMETER (BIT SIZE)

22 Inches 0 Feet 300 Feet
____ Inches _____ Feet _____ Feet
____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
<u>12"</u>	<u>24.20</u>	<u>.188</u>	<u>+2'</u>	<u>300'</u>

PERFORATIONS:

Type Perforation Louver Size Perforation 1/8"
From 118 Feet to 300 Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: Yes No SEAL TYPE:
Seal Depth 30' 50' Neat Cement
 Cement Grout

PLACEMENT METHOD: Pumped Concrete Grout
 Poured Bentonite

GRAVEL PACKED: Yes No
From 50 Feet to 300 Feet

9. WATER LEVEL

Static Water Level 30 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature cold F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. 2362
ON SITE

Signed Roger Mitchell
By driller performing actual drilling on site or contractor

Dated 10-23-09

Notes: Clean out to total depth. Perforated from 300' to 30', pumped 196 bags of bentonite grout to within 30' of surface. Install bridge plug at 30', add 4 bags hole plug. Pumped neat cement to surface. Cut casing BGL. WGS84 N39 0.859 W119 3.913 Log# 18784.

Date Started 10-7-09 Date Completed 10-14-09

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Develop

	GPM	DRAWDOWN	TIME (HRS)