

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33562

1. OWNER Mary Love ADDRESS AT WELL LOCATION Turner Ranch Rd
 MAILING ADDRESS PO Box 103 Panaca Nv.
Panaca Nv. 89042
 2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 2 N. OR. 68 E. Lincoln County
 PERMIT NO. _____ Issued by Water Resources Parcel No. 012-210-35 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy, clay		0	66	66
Silt, sand	X	66	81	15
Clay		81	90	9
Sandy clay		90	136	46
sand, gravel	X	136	161	25
clay		161	180	19
37° 45.768 N				
114° 25.600 W				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 15 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22.3	.250	+ 2	20
8	12	SDR 17	20	180

Perforations:
 Type perforation Factory Screen
 Size perforation .032 slot
 From 80 feet to 180 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 54' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 180 feet

DCNR/DWR RECEIVED
 JUN 23 2009
LAS VEGAS OFFICE

Date started May 10, 2008
 Date completed May 12, 2008

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150		4 hrs

9. WATER LEVEL
 Static water level 63.4 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 51 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Webber Drilling Contractor
 Address PO Box 40 Contractor
Overton Nv. 89040
 Nevada contractor's license number issued by the State Contractor's Board 0025887
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
 Signed Bryan Anzalone
 By Driller performing actual drilling on site or contractor
 Date June 11, 2008