WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109157
Permit No.
Basin 162

NOTICE OF INTENT NO. 33194

1. OWNER KENNETH R & MARY ANN GATLIN
MAILING ADDRESS 1210 E BRIDGER ST
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1210 E BRIDGER ST.

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 21S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources
44-722-06 Parcel No.
MESA OESTE ESTATES Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8" WELL		0	140	140
CLAY		140	156	16
CALICHE	WB	156	165	9
CLAY		165	180	15
CALICHE	WB	180	188	8
CLAY		188	206	18
CALICHE	WB	206	220	14
CLAY		220	230	10
CALICHE	WB	230	240	10

N 36° 07'31.0"
W 115° 59'20.3"

Date started 10/26/2009 , 19__
Date completed 10/26/2009 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXIST 8"	Inches	0	Feet	140	Feet
7 7/8	Inches	140	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.06	.248	0	240
EXT 8			0	140

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal EXISTING
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 125 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 10/27/2009

USE ADDITIONAL SHEETS IF NECESSARY