STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109240
Permit No. 73319
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32099

1. OWNER Billick Family Trust
MAILING ADDRESS HC 72 Box 513 Dyer NV 89010
ADDRESS AT WELL LOCATION White Mountain Rd. Hi Bar Rd Fishlake Valley
Subdivision Name: White Mountain Ranch County: Esmeralda

2. LOCATION NW ¼ NW ¼ Sec 22 T 4 N/S R 36 E
PERMIT/WAIVER No. 73319 (Issued by Water Resources) 007-601-00 (Parcel No.)
Latitude 37°34'.985" Longitude 117°58'.340"
UTM E ____ N ____ ☐ NAD 27 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☑ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand + Gravel | | 0 | 46 | 46 |
| Sand + Gravel w/Rocks | | 46 | 51 | 5 |
| Sand + Gravel | | 51 | 96 | 45 |
| Rock + Gravel | | 96 | 98 | 2 |
| Clay + Gravel | | 98 | 120 | 22 |
| Sand + Gravel | | 120 | 205 | 85 |
| Gravel | ✓ | 205 | 218 | 13 |
| Clay + Gravel | | 218 | 228 | 10 |
| Sand + Gravel | ✓ | 228 | 310 | 82 |
| Rock + Gravel | ✓ | 310 | 400 | 90 |

Date started: 9-8, 2009
Date completed: 9-12, 2009

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 12¼ | Inches | 0 | Feet | 75 | Feet |
| 10 5/8 | Inches | 75 | Feet | 400 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 Steel | +1 | 20 |
| 6 5/8 | 4.96 | .390 PVC | 20 | 400 |

Perforations:
Type of perforation Factory Screen
Size of perforation .032" inch X 1" inch 6 Row
From 400 feet to 200 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement ____ to ____ ☐ Pumped ☐ Poured
☐ Cement Grout ____ to ____ ☐ Pumped ☐ Poured
☑ Concrete Grout 25 to Surface ☐ Pumped ☑ Poured
☐ ≥30% Bentonite Grout ____ to ____ ☐ Pumped ☐ Poured
Gravel Pack: ☑ Yes ☐ No 400 to 50 ☐ Pumped ☑ Poured
Type: Pea Gravel
Bentonite Chips: ☑ Yes ☐ No 50 to 25 ☐ Pumped ☑ Poured
Type: Baroid Hole Plug 3/8 inch

7. Water Level
Static water level: 108 feet below land surface
Artesian Flow: ____ G.P.M. ____ P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budget Drilling Co. (Contractor)
Address P.O. Box 3505 Pahrump NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed ____ (By driller performing actual drilling on-site or contractor)
Date 9-15-2009

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY