

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY

Log No. 109253

Permit No. _____

Basin 145

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58677

1 OWNER Indian Hills General Improvement Dist. ADDRESS AT WELL LOCATION 960 Lehigh Circle
MAILING ADDRESS 3440 James Lee Park Road #A Carson City, NV.
Carson City, NV. 89705 Subdivision Name: _____ County: Douglas

2 LOCATION SW 1/4 NE 1/4 1/4 Sec 218 140 S R 20 E Latitude 39° 05.091' N UTM E NAD 27
PERMIT/WAIVER No. 42861/52093 Longitude 119° 46.648' W N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3 TYPE OF WELL Domestic Irrigation Test Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? no
If yes, what is replacement well NOI? _____
Is there an existing well log? yes
If yes, what is NDWR well log #? 35069

4 EXISTING WELL CONSTRUCTION

Depth Drilled 340 Feet Depth Cased 340 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>		<u>.250</u>	<u>+2</u>	<u>340</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
<u>screens</u>	<u>.100 slot</u>	<u>230</u>	<u>340</u>

Additional Perforations:

Type of perforator used:	From	To	Number of perms per linear foot
<u>Mills Knife</u>	<u>200</u>	<u>surface</u>	<u>6</u>

5 WATER LEVEL

Static water level 92.6 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	To	Material Used	neat cement	Pumped	Poured
<u>340</u>	<u>48</u>		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

Measured static water level at 92.6' and depth of well at 325'. Installed bailer and bailed debris to 338'. Installed Mills Knife and perforated 6 rows per foot from 200' to 48' where seal was present. Installed 336' of 2" tremmie pipe and the following week we pumped in 7 yards of neat cement from bottom of well to surface. Actual well volume was 4.4 yards.

Neat Cement Fluid Weight 14.5 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 11/6/2009
Date Completed 11/13/2009

39.084941° N
119.776453° W
NAD 27 (12)

STATE OF NEVADA
DIVISION OF WATER RESOURCES

2009 NOV 23 5:55

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721

Nevada contractor's license number 39920A
issued by the State Contractor's Board

Nevada driller's license number issued by the 2265
Division of Water Resources, the on-site driller

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 11/16/2009