

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24315

1. OWNER PAINTED ROCK PARTNERS ADDRESS AT WELL LOCATION Canal Rd. East of Painted Rock
MAILING ADDRESS 910 MARK VANDENBERGHE RD, VIRGINIA CITY, NV
2. LOCATION NE 1/4 NE 1/4 Sec. 24 T. 20 S. R. 23 E. Storey County
PERMIT NO. 004-011-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other cathodic protection

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Test Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG Protection

Material	Water Strata	From	To	Thickness
Lt Brown silt w gravel/cobble		0	32	32
Blue green gravel/cobble		32	58	26
Brown sand stone/silt stone		58	80	22
Dr Brown gravel		80	100	20
Blue grey gravel		100	143	43
Blue grey clay stone		143	168	25
water bearing zone	X	168	173	5
Blue grey silt/clay stone		173	190	17
Blue grey clay stone		190	215	25
Blue Black sandstone		215	227	12
Easier drilling		227	270	43
Easier drilling		270	280	10
Dr Blue sand stone hard		280	312	32
Brown/Black sand stone		312	332	20
same harder drilling		332	360	28
Blue/Black sand stone		360	380	20
Black gravel/cobbles		380	404	24

39.592390° N
119.339756° W
N80 27 34

N 39° 35.537'
W 119° 20.445'

WGS 84

8. WELL CONSTRUCTION
Depth Drilled 404 Feet Depth Cased 404 Feet

HOLE DIAMETER (BIT SIZE)
From 10" To 404 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>.308</u>	<u>0</u>	<u>279</u>

Perforations:
Type perforation Drilled
Size perforation 1/8 inch
From 279 feet to 404 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 2' to 260' Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
coke breeze
Gravel Packed: Yes No
From 260 feet to 404 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gregg Drilling & Testing Contractor
Address 950 Howe Rd. Martinez, CA 94553 Contractor
Nevada contractor's license number C23-0038113 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2322
Signed [Signature] By driller performing actual drilling on site or contractor
Date 10/20/09

Date started 9/22, 20 09
Date completed 9/25, 20 09

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>48:11:11</u>	<u>6-40N600Z</u>