STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109315
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33554

1. OWNER Klien Felder
MAILING ADDRESS 4835 Longley Ln.
Reno, NV 89502

ADDRESS AT WELL LOCATION 1630 Kleppe Ln.
Sparks, NV
Subdivision Name:
County: WASHOE

2. LOCATION NW ¼ SW ¼ Sec 11 T 19 N R 20 E
PERMIT/WAIVER No. 034-392-02
issued by Water Resources
Parcel No.

Latitude 39.526°
Longitude -119.712°
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Gravel		0	10'	10
Finer sand		10'	15'	5
	13'			
Sandy clay		15	30	15

39.526088° N
119.710980° W
N40 27 (14)

Date started: 8/1, 20 09
Date completed: 8/2, 20 09

7. Water Level
Static water level: 13' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEER'S OFFICE
2009 DEC -3 AM 10:52

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC.	Sch 40	0	30

Perforations:
Type of perforation Factory slot
Size of perforation .020
From 10 feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 6 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 30 ☐ Pumped ☒ Poured
Type: #12 sand
Bentonite Chips: ☒ Yes ☐ No 6 to 8 ☐ Pumped ☒ Poured
Type: 7/8" Holeplug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elite Drilling Inc.
Address (Contractor) 4255 W. Post rd.
Las vegas NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on-site or contractor)
Date 11/30/09

(Rev. 06-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627