

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 109320  
Permit No. \_\_\_\_\_  
Basin 105



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62926

1. OWNER Indian Hills General Improvement District ADDRESS AT WELL LOCATION MW-1 Southeast of Intersection of S. Sunridge Drive and U.S. Highway 395  
MAILING ADDRESS 3394 James Lee Park Road Carson City, Nevada, 89705 Subdivision Name: n/a County: Douglas  
2. LOCATION SE 1/4 SE 1/4 Sec 18 T 14N N/S R 20 E Latitude N39.070544 UTM E NAD 27  NAD 27  
PERMIT/WAIVER No. M/O-1607 N/A Longitude W119.769957  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  Deepen  Other  
4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Test  Stock  Monitor  
5. WELL TYPE  Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dark brown sandy silt to sandy clay		0	6	6
Dark brown clay to sandy clay		6	11	5
Interb. Sand and Gravelly Sand		11	29	18
Brown Sandy Silt		29	31	2
Gray Sand to Silty Sand		31	42	11
Interb. Sand and Gravelly Sand		42	59.5	18
Backfilled 20 to 59.5 feet with medium bentonite chips				

9. WELL CONSTRUCTION

Depth Drilled	59.5	Feet	Depth Cased	20	Feet
---------------	------	------	-------------	----	------

HOLE DIAMETER (BIT SIZE)

	From	To		
6	Inches	0	Feet	5
4	Inches	5	Feet	59.5
	Inches		Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Schedule 40	0	20

Perforations:

Type of perforation slotted  
Size of perforation 0.020 inches  
From 5 feet to 20 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 1  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 4 to 20  Pumped  Poured  
Type: \_\_\_\_\_ #3 SAND  
Bentonite Chips:  Yes  No 1 to 4  Pumped  Poured  
Type: (AND 20-59.5 feet) medium chips

Date started: 23-Nov , 20 09  
Date completed: 24-Nov , 20 09

7. Water Level  
Static water level: 13 feet below land surface  
Artesian Flow: none G.P.M. N/A P.S.I.  
Water Temperature: N/A °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PC Exploration, Inc.  
Contractor  
Address 2905 Lesvos Court Lincoln, CA 95648  
Contractor  
0028767  
Nevada contractor's license number  
issued by the State Contractor's Board 28767-M-2223  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-2223 Sonnie Fleming  
Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 11/30/2009