WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109322
Permit No. 17691
Basin 164A

NOTICE OF INTENT NO. 34671

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 S. Valley View Blvd. Las Vegas, NV 89153
ADDRESS AT WELL LOCATION 22780 S. Las Vegas Blvd., Jean, NV

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 25 N/S R. 59 E. Clark County
PERMIT NO. 17691 Issued by Water Resources
217-13-19-006 Parcel No.
WELL Site J-1 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 9-29-09: Rig-up, Trip in with 2 5/8 tremmie pipe. | | | | |
| 9-30-09: Begin pumping cement up to 213' (18 yds.). | | | | |
| 10-5-09: Finish pumping cement to surface (12 yds.) Rig-Down | | | | |
| EAST 1651766.375 | | | | |
| NORTH 3960483.5 | | | | |
| NAD 83 | | | | |
| 35.776734°N | | | | |
| 115.320065°W | | | | |
| NAD 27 (TO) | | | | |

Date started 9-29, 2009
Date completed 10-5, 2009

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

DCNR/DWR RECEIVED OCT 05 2009 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 945 Feet Depth Cased 632 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 Inches | 0 Feet | 630 Feet |
| 8 Inches | 630 Feet | 945 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 | 20 | .219 | +2 | 632 |
| | | | | |

Perforations:
Type perforation Mills Knife
Size perforation 3/16" x 12" - 4 ROWS
From 365 feet to 630 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 366' 2" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JASON E. SHAW
Address 1001 S. Valley View Blvd. #125 Contractor
Las Vegas, NV 89153 Contractor
Nevada contractor's license number issued by the State Contractor's Board N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller WW-LTD-2171
Signed Jason E. Shaw By driller performing actual drilling on site or contractor
Date 10-6-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627