

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109330
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32204

1. OWNER T-eleven Inc
MAILING ADDRESS c/o RUTAY DEPT PO BOX 711
Dallas TX 75221

ADDRESS AT WELL LOCATION 4325 W Sahara
Las Vegas NV
Subdivision Name: _____ County: CLARK

2. LOCATION NW 1/4 NE 1/4 Sec 7 T 21 NR 61 E
PERMIT/WAIVER No. 8-000436 16207501001
Issued by Water Resources Parcel No. _____

Latitude 36.0838.50 N UTM E NAD 27
Longitude 115.11.58.40 N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPLAIT</u>		<u>0</u>	<u>3"</u>	<u>3"</u>
<u>grovel sand</u>		<u>3"</u>	<u>1'</u>	<u>9"</u>
<u>sand grovel</u>		<u>1'</u>	<u>12</u>	<u>11'</u>
<u>caliche</u>		<u>12</u>	<u>14 1/2</u>	<u>2 1/2'</u>
<u>clay grovel</u>		<u>14 1/2</u>	<u>18</u>	<u>3 1/2'</u>
<u>grovel sand clay</u>		<u>18</u>	<u>22</u>	<u>4'</u>
<u>sand grovel clay</u>		<u>22</u>	<u>32</u>	<u>10'</u>
<u>caliche</u>		<u>32</u>	<u>33</u>	<u>1'</u>

9. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 32 Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
8" Inches 0 Feet 32' Feet
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>5/16 40</u>	<u>0</u>	<u>32</u>

Perforations:
Type of perforation Slotted Slit
Size of perforation 0.02
From 29 feet to 32 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout 5' to 27 Pumped Poured
 Concrete Grout 0 to 3' Pumped Poured
 30% Bentonite Grout to _____ Pumped Poured
Gravel Pack: Yes No 27 to 33 Pumped Poured
Type: 3" Silver Sand
Bentonite Chips: Yes No 3' to 5' Pumped Poured
Type: 3/8" Hole Plug

Date started: 10-30-09 :20 09
Date completed: 10-31-09 :20 09

7. Water Level
Static water level: 23 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Contractor
Address 7150 Placid Street Contractor
Las Vegas NV 89119
Nevada contractor's license number _____
issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12097
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 11-2-09