

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 109333  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34214

1. OWNER 7-ELEVEN FOOD STORE 29646 ADDRESS AT WELL LOCATION 4325 W SAHARA  
MAILING ADDRESS C/O 7-ELEVEN INC LAS VEGAS NV 89102  
P.O. BOX 711 DALLAS TX 75221  
Subdivision Name: \_\_\_\_\_ County: \_\_\_\_\_

2. LOCATION NW 1/4 NE 1/4 Sec 7 T 21 N SR 61 E Latitude 36° 08' 38.23 UTM E  NAD 27  
PERMIT/WAIVER No. 162-07-501 .001 Longitude 115° 11' 58.37 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  
 Municipal/Industrial  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		1.0	1.25	0.25
STONE FILL		1.25	1.0	0.25
SILT CLAY		1.0	5.0	4.0
CALICHE		5.0	9.0	4.0
SILT CLAY		9.0	14.0	5.0
CALICHE		14.0	16.0	2.0
SILT CLAY	YES	16.0	30.0	14.0
CALICHE		30.0	33.0	3.0

FACILITY I.D. NO. 8-000436

9. WELL CONSTRUCTION

Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>12</u>	0	33	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>SCH 40</u>	<u>0</u>	<u>33</u>

Perforations:

Type of perforation MAJLINE SLOT  
Size of perforation 1.020

From 13 feet to 33 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 1  Pumped  Poured  
 ≥30% Bentonite Grout 1 to 9  Pumped  Poured

Gravel Pack:  Yes  No 11 to 33  Pumped  Poured  
Type: NO. 3

Bentonite Chips:  Yes  No 9 to 11  Pumped  Poured  
Type: 3/8 SEAL

7. Water Level

Static water level: 26 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

**DCNR/DWR RECEIVED**  
FEB 23 2009

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EAGLE DRILLING Contractor  
Address 7150 PLACID ST LAS VEGAS NV 89119 Contractor

Nevada contractor's license number 51266  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 2357  
Division of Water Resources, the on-site driller

Signed MUD I WALTER  
By driller performing actual drilling on-site or contractor  
Date 2-24-2009