STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109334
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34214

1. OWNER 7-ELEVEN FOOD STORE 29646
MAILING ADDRESS P.O. BOX 711 DALLAS TX 75221
C.O. 7-ELEVEN INC.

ADDRESS AT WELL LOCATION 4325 W. SAHARA
LAS VEGAS NV. 89102
Subdivision Name: County: CLARK

2. LOCATION NW ¼ NE ¼ Sec 7 T 21 S R 61 E
PERMIT/WAIVER No. 162-07501-001
Issued by Water Resources Parcel No.

Latitude 36° 08 39.61
Longitude 115 11.5712
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	.25	.25
STONE FILL		.25	1.0	.75
SILTY CLAY		1.0	6.0	5.0
CALCHE		6.0	9.0	3.0
SILTY CLAY		9.0	14.0	10.0
CALCHE		14.0	16.0	2.0
SILTY CLAY	YES	16.0	30.0	14.0
CALCHE		30.0	33.0	3.0
FACILITY ID. NO. 8-000436				

Date started: 2-19 , 20 09
Date completed: 2-19 , 20 09

7. Water Level
Static water level: 24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
FEB 23 2009
LAS VEGAS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	33 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40	0	33

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 13 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 0 to 1 ☐ Pumped ☒ Poured
☒ ≥30% Bentonite Grout 1 to 9 ☒ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 11 to 33 ☐ Pumped ☒ Poured
Type: No. 3
Bentonite Chips: ☒ Yes ☐ No 9 to 11 ☐ Pumped ☒ Poured
Type: 3/8" SEAL

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST LAS VEGAS NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Neil L Winton (By driller performing actual drilling on-site or contractor)
Date 2-24-2009

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)
(NSPO 3-08)
(O) 627