STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109347
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32347

1. OWNER GB NEVADA REAL ESTATE
MAILING ADDRESS 1811 N 24TH ST. #6 PHOENIX AZ 85008

ADDRESS AT WELL LOCATION 3873 LAS VEGAS BLVD, SOUTH LAS VEGAS NV
Subdivision Name: N/A County: CLARK

2. LOCATION SW ¼ NW ¼ Sec 28 T 21 N/S R 61 E
PERMIT/WAIVER No. N/A (Issued by Water Resources) 162-28-201-001 Parcel No.
Latitude 36°05' 49.34" S Longitude 115° 10' 19.88" W
UTM E N ☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDS/GRAVELS	N/A	0'	7'	7'
CALICHE	N/A	7'	12'	5'
SANDS/GRAVELS	N/A	12'	15'	3'
CALICHE	N/A	15'	23'	8'

Date started: 7-22, 20 09
Date completed: 7-24, 20 09

9. WELL CONSTRUCTION
Depth Drilled 23' Feet Depth Cased 23' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0'	Feet	23'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.05	.237"	0'	18'
4"	2.05	.237"	18'	23'

Perforations:
Type of perforation MACHINE SLOTTED PVC
Size of perforation .020"
From 18' feet to 23' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 1' to 13' ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 16' to 23' ☐ Pumped ☒ Poured
Type: 8/12 SAND
Bentonite Chips: ☒ Yes ☐ No 13' to 16' ☐ Pumped ☒ Poured
Type: ¼" BENTONITE PELLETS

7. Water Level
Static water level: 22 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED AUG 10 2009 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NAVID MESSINA (ENVIRO-DRILL) Contractor
Address 3737 E. BROADWAY RD Contractor
PHOENIX AZ 85040
Nevada contractor's license number issued by the State Contractor's Board 0058037
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2378
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-31-09

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY