

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109348
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32348

1. OWNER G3 NEVADA REAL ESTATE ADDRESS AT WELL LOCATION 3873 Las Vegas Blvd, South
MAILING ADDRESS 1811 N. 24th St 96 Phoenix AZ 85008 LAS VEGAS NV
Subdivision Name: N/A County: CLARK

2. LOCATION S01/4 NW1/4 Sec 28 T 21 N R 61 E Latitude 36°05'49.34" S UTM E NAD 27
PERMIT/WAIVER No. N/A 162-28-201-001 Longitude 115°10'19.88" W N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND/GRAVELS</u>	<u>N/A</u>	<u>0'</u>	<u>7'</u>	<u>7'</u>
	<u>N/A</u>	<u>7'</u>	<u>13'</u>	<u>5'</u>
	<u>N/A</u>	<u>12'</u>	<u>15'</u>	<u>3'</u>
	<u>N/A</u>	<u>15'</u>	<u>23'</u>	<u>8'</u>

7. Water Level
Static water level: 22' feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 23' Feet Depth Cased 23' Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>10'</u>	<u>0'</u>	<u>23'</u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>	<u> </u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>2.05</u>	<u>.237"</u>	<u>0'</u>	<u>18'</u>
<u>4"</u>	<u>2.05</u>	<u>.237"</u>	<u>18'</u>	<u>23'</u>

Perforations:

Type of perforation MACHINE SLETTED PVC
Size of perforation .020"

From 18' feet to 23' feet
From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 1' to 13' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 16' to 23' Pumped Poured
Type: 8-12 SAND

Bentonite Chips: Yes No 13' to 16' Pumped Poured
Type: 1/4" BENTONITE PELLETS

Date started: 07-22, 20 09
Date completed: 07-24, 20 09

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DAVID MESSINA Contractor
Address 3737 E. BROADWAY RD. PHOENIX AZ 85040 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0058031
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2378

Signed David Messina
By driller performing actual drilling on site or contractor
Date 7/31/09