STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109361
Permit No.
Basin 180

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65164

1. OWNER Paramprett Investments, LLC.
MAILING ADDRESS 20255 Cold Springs Road Reno, NV
NW SW 20 21N 18E

ADDRESS AT WELL LOCATION 20255 Cold Springs Road Reno, NV
Facility ID - 4-000744
Subdivision Name: County: Washoe

2. LOCATION ~~NE~~ ¼ ~~NE~~ ¼ Sec ~~36~~ T ~~19N~~ N/S R ~~28~~ E
PERMIT/WAIVER No. 087-283-01 (issued by Water Resources) Parcel No.
Latitude N39°40'07.67" Longitude W119°59'41.91"
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Silty Sand Clay		15	25	10

39.668797°N
119.994975°W
NAD 27 (T)

Date started: 20-Oct, 20 09
Date completed: 21-Oct, 20 09

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	25

Perforations:
Type of perforation: Slot
Size of perforation: .020

From 15	feet to 25	feet	
From	feet to	feet	
From	feet to	feet	
From	feet to	feet	
From	feet to	feet	

Annular Seal: [X] Yes [ ] No

[X] Neat Cement	0 to 6	[ ] Pumped	[X] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] ≥30% Bentonite Grout	to	[ ] Pumped	[ ] Poured

Gravel Pack: [X] Yes [ ] No 8 to 25 [ ] Pumped [X] Poured
Type: Sand #3
Bentonite Chips: [X] Yes [ ] No 6 to 8 [ ] Pumped [X] Poured
Type: Medium

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Cascade Drilling, L.P.
Address (Contractor) 3632 Omec Circle
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the *State Contractor's Board* C23-0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1977
Signed (By driller performing actual drilling on site or contractor)
Date 12/3/2009

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY