WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109382
Permit No.
Basin 162

NOTICE OF INTENT NO. 33198

1. OWNER LEONARD NEWMAN & AUDREY TRUST
MAILING ADDRESS 2211 SHADY LN.
PAHRUMP, NV

ADDRESS AT WELL LOCATION 2211 SHADY LN.

2. LOCATION SE 1/4 NE 1/4 Sec. 7 T 20S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 036-161-04 (Parcel No.) J. LAWRENCE PROPERTY (Subdivision Name)

3. WORK PERFORMED
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0	4	4
CLAY		4	36	32
CALICHIE		36	48	12
CLAY		48	68	20
CALICHIE		68	75	7
CLAY		75	108	33
CALICHIE	WB	108	119	11
CLAY		119	136	17
CALICHIE	WB	136	148	12
CLAY		148	169	21
CALICHIE	WB	169	175	6
CLAY		175	185	10
CALICHIE	WB	185	194	9
CLAY		194	200	6

N 36° 13' 48.6
W 116° 03' 15.1

DCNR/DWR
RECEIVED
NOV 30 2009
LAS VEGAS OFFICE

Date started 11/18/2009 , 19__
Date completed 11/25/2009 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.06	.248	0	200

Perforations:
Type perforation SAW CUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 11/25/2009

USE ADDITIONAL SHEETS IF NECESSARY