

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 109383
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33198A

1. OWNER LEONARD NEWMAN & AUDREY TRUST
 MAILING ADDRESS 2211 SHADY LN.
PAHRUMP, NV
 2. LOCATION SE 1/4 NE 1/4 Sec. 7 T 20S
 PERMIT NO. 036-161-04
 Issued by Water Resources _____ Parcel No. _____

ADDRESS AT WELL LOCATION 2211 SHADY LN.
 #/S R 53 E NYE County
J. LAWRENCE PROPERTY
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
PER 8" STEEL WELL WITH HOLTZ AIR PREFORATOR. FROM 100 FT. TO 20 FT. HIT CEMENT @ 20 FT. PUMP BENTONITE GROUT FROM 100 FT TO 50 FT USING 1 1/4" TRIMIE PIPE. PUMP NEAT CEMENT FROM 50 FT. TO SURFACE USING 1 1/4" TRIMIE PIPE.				
N 36° 13' 48.4"				
W 116° 03' 15.1"				

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 EXST. 8" Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXST	8"	STEEL WELL		

Perforations:
 Type perforation SAW CUT
 Size perforation 1 1/4
 From _____ 20 feet to _____ 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal EXISTING
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
 Contractor
 Address 1220 E MANSE RD
 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 11/25/2009

Date started 11/18/2009, 19____
 Date completed 11/25/2009, 19____

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	Draw Down (Feet Below Static)	Time (Hours)
G.P.M.			

