STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109389
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34917

1. OWNER S. House ~~Motein~~ motel L.P.
MAILING ADDRESS 294 Convention Center Dr.
Las Vegas, NV,89109

ADDRESS AT WELL LOCATION Same as Owner
MW-18
Subdivision Name: County: clark

2. LOCATION SE ¼ SE ¼ Sec 9 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-09-803-001
Issued by Water Resources Parcel No.

Latitude 36. 133113
Longitude 115.159126
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	
Silty Sand		2	6	4
Clayey Sand		6	9	3
Silty Sand		9	10	1
Clayey Gravel		10	12	2
Cemented Sand & Gravel		12	14	2
Silty Gravel		14	20	6
Cemented Sand & Gravel		20	23	3
Sandy Clay		23	28	5
Clayey Gravel		28	32	4
Cemented Sand & Gravel		32	34	2

Date started: 7-May , 20 09
Date completed: 7-May , 20 09

9. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	34	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.70	Sch 40	0	34

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 18 feet to 34 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 18 to 34 ☐ Pumped ☒ Poured
Type: # 3 Silica
Bentonite Chips: ☒ Yes ☐ No 2 to 18 ☐ Pumped ☒ Poured
Type: 3/8 chips

7. Water Level
Static water level: 28.8 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

DCNR/DWR RECEIVED
JUN 03 2009
LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration &wells
Contractor
Address 570 corinthian way
Contractor
N Las Vegas 89030
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6-1-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY