

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY 109407  
Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin 104

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62648

1 OWNER Parks Dept, Carson City ADDRESS AT WELL LOCATION 601 Old Clear Creek Rd  
MAILING ADDRESS 3303 Butti Way, #9 Carson City, NV 89701 Carson City, NV 89705  
Carson City, NV 89701 Subdivision Name Fuji Park Pond County Carson City

2 LOCATION SE 1/4 SE 1/4 Sec 31 T 15N N/S R 20 E Latitude 39°06'50.99" UTM E  NAD 27  
PERMIT/WAIVER No. DEW-80 1520-009-303-003 Longitude 119°46'27.30" N  NAD 83/WGS 84

Issued by Water Resources Parcel No

3 Temp Dewatering TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? no  
If yes, what is replacement well NO? \_\_\_\_\_

Is there an existing well log? yes  
If yes, what is NDWR well log #? 109119

4 EXISTING WELL CONSTRUCTION

Depth Drilled 40 Feet Depth Cased 40 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	40

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

If casing was left in place, please show where additional perforations were made:  
Additional Perforations

Existing Perforations:

Type of perforation	Size of perforation	From	To
machine slotted	0.032	20	40

Type of perforator used:

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL

Static water level 7 feet below land surface  
Artesian flow n/a G.P.M. n/a P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used		
2	10-12	feet	concrete grout	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
				<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
				<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
				<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
				<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
				<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

6 Additional Notes or Comments

39.114255° N  
119.773236° W N9027 (T)

Temp Dewatering Well # 9

2009 NOV 30 PM 12:46  
STATE ENGINEERING & PILING

Neat Cement Fluid Weight 94/7 lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite

Date Started 11/16/2009  
Date Completed 11/16/2009

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Viking Drillers Inc. Contractor  
Address 801 Northport Dr. Contractor  
West Sacramento, CA 95691

Nevada contractor's license number issued by the State Contractor's Board 0034680  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2090

Signed \_\_\_\_\_  
By driller performing actual drilling on site or contractor  
Date 11/24/2009