Broadbent

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109528
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32215

1. OWNER KELCO LLC.
MAILING ADDRESS 1761 N. COUNTRY SPRINGS CIR. BOUNTIFUL UT. 84010

ADDRESS AT WELL LOCATION 250 SOUTH MOAPA BLVD OVERTON, NV. 89040
Subdivision Name:
County: CLARK

2. LOCATION NW ¼ SE ¼ Sec 13 T 16 N/S R 67 E
PERMIT/WAIVER No. 0703701638
Issued by Water Resources Parcel No.

Latitude 36° 32.364
Longitude 114° 26.581
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CONCRETE		0	.25	.25
SAND + STONE FILL		.25	1	.75
SAND WITH SILT		1	12	11
SILTY CLAY	YES	12	25	13
FACILITY I.D NO. 8-001032				

Date started: 5-4, 20 09
Date completed: 5-4, 20 09

7. Water Level
Static water level: 13.6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	25

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 1 ☐ Pumped ☒ Poured
☒ ≥30% Bentonite Grout 1 to 3 ☐ Pumped ☒ Poured

Gravel Pack: ☒ Yes ☐ No 3 to 25 ☐ Pumped ☐ Poured
Type: NO. 3
Bentonite Chips: ☒ Yes ☐ No 1 to 3 ☐ Pumped ☒ Poured
Type: 3/8" SEAL

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST. LAS VEGAS NV. 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed (By driller performing actual drilling on-site or contractor)
Date 5-9-2009

RECEIVED MAY 13 2009

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-08)
(NSPO 3-08)
(O) 627