STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109588
Permit No.
Basin 091

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64103

1. OWNER Boomtown Hotel & Casino, Inc
MAILING ADDRESS P.O. Box 399 Verdi, NV 89439
ADDRESS AT WELL LOCATION 2100 W. Interstate 80, Verdi, NV
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SE ¼ Sec 16 T 19N N/S R 18 E
Latitude 39.51162° N
Longitude – 119.96254° W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. WC645UST (Issued by Water Resources) 038-430-02 Parcel No.

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other x mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt & base		0	1	1
DG		1	43	42
DG & boulder	x	43	105	62

39.51710° N
119.96508° W
NAD 27 (TC)

RECEIVED 2009 APR 15 AM 10:36 STATE ENGINEERS OFFICE

Date started: 30-Mar, 20 09
Date completed: 2-Apr, 20 09

9. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 105 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	0	Feet	105	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.82	sch 80	0	105

Perforations:
Type of perforation screen
Size of perforation .040"
From 65 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 10 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 61 ☒ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 63 to 105 ☐ Pumped ☒ Poured
Type: SRI #6 sand
Bentonite Chips: ☒ Yes ☐ No 61 to 63 ☐ Pumped ☒ Poured
Type: hole plug

7. Water Level
Static water level: 65 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	40	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc (Contractor)
Address 4850 Joule St. Suite A5 (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2121
Signed Steve McKay (By driller performing actual drilling on site or contractor)
Date 4/10/2009

(Rev. 06-08)
USE ADDITIONAL SHEETS IF NECESSARY