

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 109543
Permit No. _____
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

2F-09-20

NOTICE OF INTENT NO. 65221

1. OWNER Kleinfelder
MAILING ADDRESS 4835 Langley Lane Reno Nevada 89502

ADDRESS AT WELL LOCATION P-2F-09-20

2. LOCATION NW 1/4 SW 1/4 Sec 15 T 19 N R 20 E
PERMIT/WAIVER No. m/o 1558 1034-152-01

Subdivision Name: _____ County: Washoe
Latitude 39.512548° N UTM E 26584.19 NAD 27
Longitude 119.730363° W N 4377008.03 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand (SM)		0	2	
Sand, clay (CL)		2	4	
Silty Sand (SM)		6	10	
Sand, silt (ML)		10	12	
Lean Clay (CL/CH)		12	15	
Silty Gravel w/sand (GP-GM)		15	16	
Sand with clay layers (SP+CL)		16	21	
Gravel w sand and clay (GP-GC)		21	48	
Clay Sand (SP-SC)		48	56	
Clay Gravel w/sand (GP-GC)		56	59.5	

9. WELL CONSTRUCTION
Depth Drilled 60 Feet
Depth Cased 20 Feet
HOLE DIAMETER (BIT SIZE)
From 6 Inches To 60 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch 80</u>	<u>0</u>	<u>20</u>

Perforations:
Type of perforation hor slot
Size of perforation Ø20
From 20 feet to 5 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 60 to 22 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No 21 to 3 Pumped Poured
Type: _____
Bentonite Chips: Yes No 3 to 1 Pumped Poured
Type: 3/8 bentonite chip

Date started: 12-01, 20 09
Date completed: 12-02, 20 09

7. Water Level
Static water level: 15.4 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Contractor
Address PO Box 141
Zanora CA 95698
Nevada contractor's license number 0012852
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1880
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 12/02/09

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)