

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY **109557**
 Log No.
 Permit No. **057**
 Basin

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **63722**

1. OWNER **Rob Wohle** ADDRESS AT WELL LOCATION **Antelope Valley**
 MAILING ADDRESS **HC 61 Box 169** **Battle Mtn, NV**
Battle Mtn, NV 89820 Subdivision Name: County: **Lander**

2. LOCATION **SE 1/4 NE 1/4 Sec 10 T24N R41E** Latitude **39.96970** UTM E NAD 27
 PERMIT/WAIVER NO. **77918T** Longitude **-117.34212** N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand w/Gravel		0	38	38
Lg Gravel		38	48	10
Sand & Gravel		48	73	25
Gravel		73	104	31
Red rock & Gravel		104	116	12
Gravel w/Sand		116	124	8
Brown Clay		124	136	12
Red Rock		136	143	7
Gray Clay w/S Gravel		143	166	23
brown Clay w/Gravel		166	173	7
Red Rock w/SM Gravel		173	183	10
Gray Clay		183	205	22
Gray Clay w/Sand		205	218	13
Brown Clay		218	226	8
Gray Clay		226	255	29
Red Rock w/Gravel		255	276	21
Gravel		276	308	32
Brown Clay		308	368	60
Hard Rock		368	376	8
Brown Clay		376	378	2
Gravel w/Clay Streaks		378	416	38
Gray Rock		416	420	4

39.969782° N
117.341182° W
NAD 27 (10)

9. WELL CONSTRUCTION

Depth Drilled **420** Feet Depth Cased **420** Feet

HOLE DIAMETER (BIT SIZE)

From	To
28 Inches	0 Feet 380 Feet
26 Inches	380 Feet 420 Feet
36 Inches	0 Feet 50 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	39.5	.109	5	50
20	65.6	.312	190	420
16	42.1	.250	0	190

30 | 118.7 Perforations: .375 | 0 | 5
 Type of perforation **Mill Cut 110-190 Louvered 190-240**
 Size of perforation **.250**

From **110** feet to **190** Mill Cut feet
 From **190** feet to **420** Louver feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement _____ to _____ Pumped Poured
 Cement Grout **0** to **50** Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No **420** to **0** Pumped Poured
 Type: **3/4" Well Rock**
 Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

7. Water Level

Static water level: **158** feet below land surface
 Artesian Flow: _____ G.P.M. _____ P.S.I.
 Water Temperature: **cool** °F
 Quality: **Unknown**

8. WELL TEST DATA

Customer	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
did own	test pump		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Parsons Drilling, Inc.** (CONTRACTOR)
 Address **P.O. box 1265** (CONTRACTOR)
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board **29064**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **228**

Signed _____
 By driller performing actual drilling on site or contractor
 Date **3/27/2009**

RECEIVED
 2009 APR 14 AM 9:16
 STATE ENGINEER'S OFFICE