AS-5

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109604
Permit No.
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65110

1. OWNER Kyle Kochanski (For Chevron)
MAILING ADDRESS 6111 Bollinger Cyn. Rd. Room 3668 San Ramon, CALIF. 94583
ADDRESS AT WELL LOCATION 1922 Victorian Ave Sparks, Nevada 89431
Subdivision Name: County: WASHOE

2. LOCATION SW¼ SW¼ Sec 5 T 19 N S R 20 E
PERMIT/WAIVER No. 21-1497 (Issued by Water Resources) 032-065-10 (Parcel No.)
Latitude N 39° 32' 7.881" UTM E
Longitude W 119° 46' 9.752" N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor VAPOR ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobbles, gravels, sand		0	20	20
sand		20	30	10
39.535611°N				
119.768353°W				
NAD 27 (TN)				

2009 DEC 22 AM 10:58

Date started: 11/21, 2009
Date completed: 11/23, 2009

7. Water Level
Static water level: NA feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.720	0.154	0	30

Perforations:
Type of perforation SLOT
Size of perforation 0.010
From 30 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 25' to 6" ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 30 to 27 ☐ Pumped ☒ Poured
Type: 8/12
Bentonite Chips: ☒ Yes ☐ No 27 to 25 ☐ Pumped ☒ Poured
Type: 3/8 chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 1333 W. 9th ST. (Contractor)
UPLAND, CALIF. 91786
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2405
Signed [signature] By driller performing actual drilling on-site or contractor
Date 12-10-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627