

AS-4

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109605
Permit No. 487
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65110

1. OWNER Kyle Kochanski (For Chevron)
MAILING ADDRESS 6111 Bolinger Pkwy. Rd. Room 3068
San Ramon, CALIF. 94583

ADDRESS AT WELL LOCATION 1922 VICTORIAN AVE
SPARKS, NEVADA 89431
Subdivision Name: County: WASHOE

2. LOCATION SW 1/4 SW 1/4 Sec 5 T 19 N R 20 E
PERMIT/WAIVER No. 21-1497 032-065-10
Issued by Water Resources Parcel No.

Latitude N 39° 32' 78.81" UTM E. NAD 27
Longitude W 119° 46' 9.752" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor VAPOR Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other SOUNIC

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Cobbles, gravels, sand		0	20	20
Sand		20	30	10
39.535611 N				
119.769353 W				
NAD 27				

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet
HOLE DIAMETER (BIT SIZE)
From 8 Inches To 30 Feet
Inches Feet
Inches Feet
Inches Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.720	0.154	0	30

Perforations:
Type of perforation 3.07
Size of perforation 0.010
From 30 feet to 29 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: Yes No
 Neat Cement Pumped Poured
 Cement Grout 25' to 6.5' Pumped Poured
 Concrete Grout Pumped Poured
 ≥30% Bentonite Grout Pumped Poured
Gravel Pack: Yes No 30 to 27 Pumped Poured
Type: SLIZ
Bentonite Chips: Yes No 27 to 25 Pumped Poured
Type: 3/8 chips

Date started: 11/22, 20 09
Date completed: 11/24, 20 09

7. Water Level N/A feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	NA		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: BOB LANGYEAR Contractor
Address: 1333 W. 9th St. Contractor
UPLAND, CALIF. 91786
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2405
Signed: [Signature] By driller performing actual drilling on-site or contractor
Date: 12-10-09