STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109627
Permit No.
Basin 044

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62052

1. OWNER Carefree Homes
MAILING ADDRESS 3260 South Redwood
Salt Lake City, Ut 84119

ADDRESS AT WELL LOCATION 6277 Filmore, Elko, NV
Subdivision Name: Humbold River Ranches #9 / County: Elko

2. LOCATION SE ¼ SW ¼ Sec 31 T 36N N/S R 57 E
PERMIT/WAIVER No. 012-005-008 (Issued by Water Resources) Parcel No.

Latitude 40°57.566N
Longitude 115°35.576W
UTM E N
☐ NAD 27 ☐ NAD 83 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	2	2
Sand & Gravel		2	11	9
Hard Pan		11	39	28
Clay		39	125	86
Sand & Gravel	X	125	127	2
Clay		127	138	11
Sand & Gravel		138	142	4
Clay		142	157	15
Sand & Gravel	X	157	159	2
Clay		159	168	9
Sand & Gravel	X	168	180	12

40.959513 N
115.592034 W
NAD 27 (TA)

RECEIVED 2008 JUL -2 AM 11:41 STATE ENGINEER'S OFFICE

Date started: 6-Jun, 20 08
Date completed: 8-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-17	20	180

Perforations:
Type of perforation: Screen
Size of perforation: 0.032
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 21 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 54 to 180 ☐ Pumped ☒ Poured
Type: 3/8 pea gravel
Bentonite Chips: ☒ Yes ☐ No 21 to 54 ☐ Pumped ☑ Poured
Type: 3/8 Kiwk Plugg

7. Water Level
Static water level: 63 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	45		7.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig Sr dba Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site of contractor)
Date 6-30-08

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY