

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 109636

Permit No. \_\_\_\_\_  
Basin φ76

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57732

1. OWNER Jackson Food Stores ADDRESS AT WELL LOCATION 210 US Hwy 40E  
MAILING ADDRESS 3450 E. Commercial Ct Fernley NV  
Meridian ID 83642 Subdivision Name: N/A County: LYON

2. LOCATION SE 1/4 SW 1/4 Sec 7 T 20 N R 25 E Latitude N 39° 36.457' UTM E  NAD 27  
PERMIT/WAIVER No. NDEP# 3-000166 021-232-18 Longitude W 119° 13.281' N  NAD 83 (WGS 84)

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW#3</u>				
<u>black A/C</u>		<u>0</u>	<u>1/2</u>	<u>1/2</u>
<u>brown sand w/silt</u>		<u>1/2</u>	<u>9</u>	<u>8 1/2</u>
<u>brown silty sand w/clay</u>		<u>9</u>	<u>14</u>	<u>5</u>
<u>brown silty sand w/clay</u>		<u>14</u>	<u>26</u>	<u>12</u>
<u>brown silty sand w/clay</u>	<u>23.5</u>	<u>9</u>	<u>26</u>	<u>17</u>
<u>brown clayey sand w/silt</u>		<u>26</u>	<u>30</u>	<u>4</u>

39.607722° N  
119.220359° W  
NAD 27 (83)

9. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>10.5</u> Inches	<u>0</u>	<u>30</u>	Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch 40</u>	<u>30</u>	<u>1/2</u>

Perforations:

Type of perforation slotted screen

Size of perforation 0.020

From	To	feet to	feet
<u>30</u>	<u>10</u>		feet
From		feet to	feet
From		feet to	feet
From		feet to	feet

Annular Seal:  Yes  No

<input checked="" type="checkbox"/> Neat Cement	<u>6</u> to <u>1.5</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	<u>1.5</u> to <u>0</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> ≥80% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 30 to 8  Pumped  Poured

Type: CEMEX SAND #3

Bentonite Chips:  Yes  No 8 to 6  Pumped  Poured

Type: Puregold medium (ceteo)

Date started: 10/2/08 20 08  
Date completed: 10/2/08 20 08

7. Water Level

Static water level: 23.5 feet below land surface

Artesian Flow: - G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_

Water Temperature: WARM °F

Quality: Mucky

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dale Letman Contractor

Address 520 Edison Way Contractor

Reno NV 89502

Nevada contractor's license number 0062596 RSI Drilling

issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976

Signed Dale Letman By driller performing actual drilling on site or contractor

Date 10/2/08

(Rev. 05-04)

USE ADDITIONAL SHEETS IF NECESSARY