

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **63080**

1. OWNER Nevada Geothermal Power ADDRESS AT WELL LOCATION Jungo Rd. Winnemucca NV.  
 MAILING ADDRESS 657 Anderson St. Winnemucca NV. 89445

2. LOCATION SW 1/4 NW 1/4 Sec. 35 T. 36 N. R. 34 E. Humboldt County  
 PERMIT NO. W-630A/77056 ~~29956~~ 5-341-36 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	5	5
Sand		0	40	35
sand, Gravel		80	120	80
sand, Gravel, Brown clay		120	160	40
sand, Gravel, little clay		160	180	20
Sand, Gravel		180	220	40
Sand, Gravel, Red silt		220	260	40
Sand, Red silt		260	300	40

Drilled hole to depth obtained  
 water sample plugged hole  
 per state log 51.

Plugged 0 to 50 cement  
 50 to 100 hole plug  
 100 to 300 Abandon the string

GPS N 40.953.191  
 W 118.137.576  
 NAD 27 (TM)

\* See plugging log 1091652

Date started 8.21 2008  
 Date completed 8.21 2008

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 300 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
N/A				

Perforations: N/A  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality Clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Firstgold Corp. Contractor  
 Address P.O. Box 6 Lovelock NV. Contractor

Nevada contractor's license number 0071020  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 2032  
 Division of Water Resources, the on-site driller

Signed Herald Mout  
 By driller performing actual drilling on site contractor  
 Date 9-24-08

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>03:11:11</u>	<u>0.25</u>