— Plugging —

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 109654
Log No.
Permit No.
Basin Ø31

NOTICE OF INTENT NO. 63081

1. OWNER Nevada Geothermal Power
MAILING ADDRESS 657 Anderson St. Winnemucca NV. 89445
ADDRESS AT WELL LOCATION Jungo Rd. Winnemucca NV. 89445

2. LOCATION NW ¼ NE ¼ Sec. 35 T. 36 N/S R. 34 E. Humboldt County
PERMIT NO. W-630-A/7706 (Issued by Water Resources) ~~21056~~ 5-34-36 (Parcel No.) Subdivision Name

3. WORK PERFORMED
■ New Well ☐ Replace ☐ Recondition
☐ Deepen ■ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ■ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ■ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	40	40
Sand Rock		40	95	55
Sand Rock Gravel	~~yes~~	95	140	45
Gravel & Brown Clay				
Sand Gravel Clay	yes	140	180	40
Clay Sand	yes	180	200	20
Sand Gravel, Silt	yes	200	270	70
Sand Grey Silt	yes	270	300	30

Drilled well to depth obtained water sample abandoned well per state regs.

0 to 50 Neat Cement
50 to 140 3/8" Hole plug
140 to 300 Abantonite Slurry

GPS N40.956217
W118.127552
NAD 27 (14)

Date started 8-20, 2008
Date completed 8-20, 2008

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		.25

AM 11:20 2008 SEP 25 AM 11:33

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased NA Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		NA		

Perforations:
Type perforation NA
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ■ Yes ☐ No
Depth of Seal 50'
Placement Method: ■ Pumped ☐ Poured
Seal Type: ■ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ■ No
From feet to feet

9. WATER LEVEL
Static water level 83' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. (Contractor)
Address P.O. Box 6 (Contractor)
Lovelock NV. 89419
Nevada contractor's license number issued by the State Contractor's Board 0071020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2032
Signed Harold Montz (By driller performing actual drilling on site or contractor)
Date 9-22-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627