WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109655
Permit No.
Basin 101 A

NOTICE OF INTENT NO. 63089

1. OWNER Firstgold Corp.
MAILING ADDRESS P.O. Box 6
Lovelock NV. 89419

ADDRESS AT WELL LOCATION 7000 Coal Canyon Rd.
Lovelock NV. 89419
MW-08-03

2. LOCATION SW SE ¼ SE SE ¼ Sec. 18 T. 27 N S R 33 E Pershing County
PERMIT NO. WDCP2007105 (Issued by Water Resources) | 15-050-18 (Parcel No.) | GPS N 40° 12.304 W 118° 12.751 NAD27 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, silt, gravel	NO	0	60	60
Silt clay gravel	yes	60	110	50
heavy coarse gravel	yes	110	130	20
silt clay	yes	130	150	20
50' to 135' 3/8"	Hole plug			
40.205067°N				
118.212517°W				
NAD 22 (TT)				

Date started 9-23-, 2008
Date completed 9-24, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	NA	1

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 7/8 Inches	0 Feet	20 Feet
6 Inches	20 Feet	150 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
2"	PVC	Sched 40	0	150

Perforations:
Type perforation Machine slot
Size perforation .010
From 140 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 135 feet to 150 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. (Contractor)
Address P.O. Box 6 (Contractor)
Lovelock NV. 89419
Nevada contractor's license number issued by the State Contractor's Board 0071020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-7-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627