WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1096660
Permit No.
Basin 101A

NOTICE OF INTENT NO. 63084

1. OWNER Firstgold Corp.
MAILING ADDRESS P.O. Box 6 Lovelock NV. 89419
ADDRESS AT WELL LOCATION 7000 Coal Canyon Rd. Lovelock NV. 89419
MW-07-01

2. LOCATION ~~SE~~ NE 1/4 ~~NE~~ NW 1/4 Sec. 18 T. 27 N S R. 34 E. Pershing County
PERMIT NO. NDCP 2007105 (Issued by Water Resources) | 15-050-18 (Parcel No.) | GPS N 40° 12.587 W 118° 12.256 NAD27 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, Clay, Sand	No	0	120	120
Silt, Clay, Gravel	yes	120	150	30

50' to 125' 3/8" Hole plug

40.209783° N
118.204267° W
NAD 27 (TP)

Date started 9-17, 2008
Date completed 9-19, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	N/A	1

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	20 Feet	150 Feet
10 3/4 Inches	0 Feet	20 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch 40	0	150
6 5/8	Steel	.188	0	20

Perforations:
Type perforation Machine Slot
Size perforation .010
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 125 feet to 150 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. (Contractor)
Address P.O. Box 6 Lovelock NV. 89419 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0071020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on site or contractor)
Date 9-19-08

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627