

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY 109663
Log No. _____
Permit No. _____
Basin 088

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 63537

1 OWNER **GLORY TEMPLE CHURCH**
MAILING ADDRESS **16255 S VIRGINIA ST
RENO NV 89521**

ADDRESS AT WELL LOCATION **16255 S VIRGINIA ST
RENO NV 89521**
Subdivision Name: _____ County: **Washoe**

2 LOCATION NE 1/4 NW 1/4 Sec 284 T 10N R 20 E
PERMIT/WAIVER No. 65090 Parcel No. 045-210-01
Issued by Water Resources

Latitude 39.37355°N UTM E NAD 27
Longitude 119.74660°W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? **YES**
If yes, what is replacement well NO? **63535**

Is there an existing well log? **NO**
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 35 N/A Feet Depth Cased 35 N/A Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	20	35

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: _____

Existing Perforations:

From	Type of perforation	Size of perforation	feet to	feet
	N/A	N/A		

Type of perforator used: **NONE**

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level 30 feet below land surface
Artesian flow N/A G.P.M. _____ P.S.I. _____
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
20	35	feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
5	20	feet	CLEAN FILL	<input type="checkbox"/>	<input checked="" type="checkbox"/>
2	3	feet	CEMENT	<input type="checkbox"/>	<input checked="" type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
**48 INCH CULVERT WITH WELL IN BOTTOM
NEAT CEMENT IN BOTTOM CLEAN FILL FROM TOP
OF NEAT CEMENT TO BOTTOM OF PIPING
ROLLED OUT PUMP AND OLD LADDER**

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 12/18/2008
Date Completed 12/18/2008

2008 DEC 22 PM 2:00
39.373639° N
119.745582° W
045-210-01

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name **CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC**
Contractor
Address **# 20 KIT KAT DRIVE**
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board **0055548**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date **12/18/2008**