

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 109672
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33695
620 Shadow Lane

1 OWNER Valley Health System LLS
MAILING ADDRESS 620 Shadow Lane
Las Vegas NV 89106

ADDRESS AT WELL LOCATION DW-3
Subdivision Name _____
County _____

2 LOCATION NW: SW 1/4 Sec 33 T 20 N/SR 61 E
PERMIT/AWAIVER No DW-1257 | 139-33-311-001
Issued by Water Resources Parcel No.

Latitude 115° 10' 00.3 UTM E _____ NAD 27
Longitude 36° 09' 8.16 N _____ NAD 83/WGS 84

3 TYPE OF WELL DW
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
Is there an existing well log? NO
If yes, what is replacement well NOI? _____
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>28.55</u>	<u>.322</u>		

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations: N/A

Existing Perforations:
Type of perforation Factory slotted
Size of perforation 1070
From 10 feet to 40 feet
From _____ feet to _____ feet


Type of perforator used: N/A
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____
From _____ feet to _____ feet Number of perfs per linear foot _____

5 WATER LEVEL
Static water level 21' feet below land surface
Artesian flow NO G.P.M. NO P.S.I.
Water temperature N/A °F Quality good

8 WELL PLUGGING MATERIALS
Material Used
From 0 feet to 40 feet Bentonite grout Pumped Poured
From _____ feet to _____ feet Pumped Poured

6 Additional Notes or Comments
Hole was Excavated down to 10' so we pulled the well & grouted from there

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout 15 % bentonite
Date Started 5-19-08
Date Completed 5-19-08



9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name WDE Exploration + Wells Contractor
Address 570 Concession way N Las Vegas NV 89030 Contractor
Nevada contractor's license number 12852 D8B
issued by the State Contractor's Board 001252
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057-T4
Signed [Signature]
By _____ performing actual drilling on site or contractor
Date 5-19-08