

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 109697  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33832

1. OWNER 4444 S. VALLEY VIEW LLC ADDRESS AT WELL LOCATION 4444 S. VALLEY VIEW BLVD.  
MAILING ADDRESS 4444 S. VALLEY VIEW BLVD. LAS VEGAS NV. 89103  
Subdivision Name: \_\_\_\_\_ County: CLARK

2. LOCATION S0 1/4 NW 1/4 Sec 20 T 21 N/S R 61 E Latitude 36° 06' 33.65" UTM E  NAD 27  
PERMIT/WAIVER No. MD 2839 16220201008 Longitude 115° 11' 21.97" N  NAD 83/WGS 84  
issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0.0	2.5	2.5
STONE FILL		2.5	7.5	5.0
BROWN SANDY SILT		7.5	5.0	4.25
SILTY BROWN CLAY		5.0	16.0	11.0
CALICHE		16.0	18.0	2.0
SILTY BROWN CLAY		18.0	28.0	10.0
SILTY MOIST CLAY	YES	28	35	7.0

9. WELL CONSTRUCTION  
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>8</u>	<u>0</u>	<u>35</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH 40</u>	<u>0</u>	<u>35</u>

Perforations:

Type of perforation MACHINE SLOT  
Size of perforation .020

From 25 feet to 35 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 25 to 35  Pumped  Poured  
Type: NO 3

Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 11-11, 20 09  
Date completed: 11-11, 20 09

7. Water Level  
Static water level: 28 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EAGLE DRILLING Contractor  
Address 7150 PLACIO ST. Contractor  
LAS VEGAS NV. 89119  
Nevada contractor's license number 51266  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 2357  
Division of Water Resources, the on-site driller  
Signed Mudr Wiktor  
By driller performing actual drilling on-site or contractor  
Date 11-12-2009