

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 109698
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33833

1 OWNER 4444 S. VALLEY VIEW LLC ADDRESS AT WELL LOCATION 4444 S. VALLEY VIEW BLVD
MAILING ADDRESS 4444 S. VALLEY VIEW BLVD LAS VEGAS NV. 89103
LAS VEGAS NV. 89103 Subdivision Name: _____ County: CLARK

2 LOCATION SW 1/4 NW 1/4 Sec 20 T 21 N/S R 41 E Latitude 36° 06' 32.65" UTM E NAD 27
PERMIT/WAIVER No. MO-2839 16220201008 Longitude 115° 11' 21.97" N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
If yes, what is replacement well NOI? _____

Is there an existing well log? YES
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>5/8 40</u>	<u>0</u>	<u>35</u>

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:
Additional Perforations: NONE

Type of perforator used: NONE

From	feet to	feet	Number of perfs per linear foot

Existing Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020

From	feet to	feet	feet

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
From <u>0</u>	feet to <u>.5</u>	feet	<u>ASPHALT</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
From <u>.5</u>	feet to <u>35</u>	feet	<u>BENTONITE</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____	feet to _____	feet	_____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____	feet to _____	feet	_____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____	feet to _____	feet	_____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From _____	feet to _____	feet	_____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

5 WATER LEVEL
Static water level 28 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

6 Additional Notes or Comments
WELLS WERE PLUGGED AFTER SAMPLING.

Neat Cement Fluid Weight 12 lbs/gal
Bentonite Grout 30 % bentonite
Date Started 11-11-09
Date Completed 11-11-09

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING Contractor
Address 7150 PLANO ST Contractor
LAS VEGAS NV. 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Matt Winter
By driller performing actual drilling on-site or contractor
Date 11-12-2009