WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY 109764
Log No.
Permit No.
Basin 110C

NOTICE OF INTENT NO. 60959 ~~60960~~

1. OWNER Hawthorne Army Depot (Kevin Shannon)
MAILING ADDRESS 25 Marine BLDG 5
Hawthorne NV. 89415
ADDRESS AT WELL LOCATION Hwy 95
Hawthorne Army Depot

2. LOCATION ~~Fwlw~~ ¼ ~~NW~~ ¼ Sec. ~~FB~~ 10 T 8 N S R 30 E Mineral County
PERMIT NO. M10-1475/9-000031
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☒ Other Boring

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	12	12
Gravelly Sand		12	34	22
Sand		34	55	21
Gravelly Sand		55	67	12
Clay		67	69	2
SAND		69	99	30
Gravelly Sand		99	102	3
Clay		102	106	4
SAND		106	107	1
38.568442°N				
118.616479°W				
NAD 27 (TR)				
~~ABandon w/ Cement Grout~~		~~107~~	~~20~~	~~87~~
ABAndon w/ Neat Cement		~~107~~	~~0~~	~~107~~
		107	0	107
[redacted] N 38° 34' 06.09"				
W 118° 37' 02.78"				
~~Datum~~ WGS 84				

Date started 12/5, 2007
Date complated 12/5, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 107 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)
6" Inches From 0 Feet To 107 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 104' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear
Contractor
Address 12464 McCann Dr.
Contractor
SANTA Fe Springs, CAL 90670
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed [signature]
By driller performing actual drilling on site or contractor
Date 2/11/08

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY J03 - SB8

(O)-627