

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **64794**

1. OWNER **Robert Shell** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **1639 Ballard St. Winnemucca NV. 89445** **4650 W. Winnemucca Blvd. Winnemucca NV. 89445**
 2. LOCATION **1/4 Sec. 2 T. 35 S. R. 37 E. Humboldt** County _____
 PERMIT NO. **75-957** Issued by Water Resources Parcel No. **013-053-38** Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand + Clay	NO	0	5	5
Sand + Gravel	NO	5	55	50
Sand + Gravel	Yes	55	150	95
N 40° 56.162				
W 117° 47.179				
NAO 83				
40.936 / 130° N				
117.785 / 352° W				
NAD 27 (TA)				
2010 JAN -7 AM 10:59				

8. WELL CONSTRUCTION
 Depth Drilled **150** Feet Depth Cased **150** Feet
 HOLE DIAMETER (BIT SIZE)
 From **10 7/8** Inches To **150** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	1.88	0	20
6 5/8	PVC	Sched 40	20	150

Perforations:
 Type perforation **Slot**
 Size perforation **1/25**
 From **130** feet to **150** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **55'** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **55** feet to **150** feet

9. WATER LEVEL
 Static water level **35** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cold** °F Quality **Clear**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Alternative Drilling** Contractor
 Address **197 Western Hills #7** Contractor
Spring Creek NV.
 Nevada contractor's license number issued by the State Contractor's Board **73955**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **730**
 Signed **Arnold Montz**
 By driller performing actual drilling on site or contractor
 Date **1-6-10**

Date started **12-18**, 20**09**
 Date completed **12-29**, 20**09**

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	75+	0	3