PLUGGED BY
NOI # 45317

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 109825
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45321

1. OWNER Minden Gardnerville Sanitation District
MAILING ADDRESS 1790 Hwy 395
Minden, NV 89423

ADDRESS AT WELL LOCATION 1790 Hwy 395
Minden, Nv 89423
Subdivision Name: County: Douglas

2. LOCATION NE ¼ NW ¼ Sec 30 T 13N N/S R 20 E
PERMIT/WAIVER No. DEW-75 (Issued by Water Resources) 1320-30-101-001 Parcel No.
Latitude N 38 57.924
Longitude W 119 46.816
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well # 5				
see Attached Boring Log				
38.965500				
119.779270				
NAD 27 (T08)				
* See plugging log # 109824				

Date started: 25-Jun, 20 08
Date completed: 25-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	30

Perforations:
Type of perforation machine slot
Size of perforation 0.032
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 12 ☐ Pumped ☒ Poured

Gravel Pack: ☒ Yes ☐ No 12 to 30 ☐ Pumped ☒ Poured
Type: 3/8 Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 10 to 12 ☐ Pumped ☒ Poured
Type: 3/8's

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc (Contractor)
Address 801 Northport Dr. (Contractor)
West Sacramento, CA
Nevada contractor's license number issued by the State Contractor's Board 0034680
Nevada driller's license number issued by the Division of Water Resources, the on-site driller DEW-2361
Signed (By driller performing actual drilling on site or contractor)
Date 7/21/2008

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY