


PLUGGED BY  
 NOI # 45317

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 109830  
 Permit No. \_\_\_\_\_  
 Basin 165 pglot 2



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45321

1. OWNER Minden Gardnerville Sanitation District  
 MAILING ADDRESS 1790 Hwy 395  
Minden, NV 89423

ADDRESS AT WELL LOCATION 1790 Hwy 395  
Minden, NV 89423  
 Subdivision Name: \_\_\_\_\_ County: Douglas

2. LOCATION NE 1/4 NW 1/4 Sec 30 T 13N N/S R 20 E  
 PERMIT/WAIVER No. DEW-75 1320-30-101-001  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude N 38 57.897 UTM E  NAD 27  
 Longitude W 119 46.845 N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. Driller PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Well # 2				
see Attached Boring Log				
<u>38.965050 N</u>				
<u>119.779753 W</u>				
<u>NAD 27 (T)</u>				
<u>2010 JUN -4 PM 11:24</u>				

9. WELL CONSTRUCTION			
Depth Drilled	Feet	Depth Cased	Feet
<u>30</u>		<u>30</u>	
HOLE DIAMETER (BIT SIZE)			
	From	To	
<u>24</u>	Inches <u>0</u>	Feet <u>30</u>	Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>3/8</u>	<u>0</u>	<u>30</u>

Perforations:  
 Type of perforation machine slot  
 Size of perforation 0.032  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout 10 to 12  Pumped  Poured  
 Gravel Pack:  Yes  No 12 to 30  Pumped  Poured  
 Type: 3/8 Pea Gravel  
 Bentonite Chips:  Yes  No 10 to 12  Pumped  Poured  
 Type: 3/8's

Date started: 24-Jun, 20 08  
 Date completed: 24-Jun, 20 08

7. Water Level  
 Static water level: 7 feet below land surface  
 Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water Temperature: cold °F  
 Quality: \_\_\_\_\_

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Viking Drillers Inc  
 Contractor  
 Address 801 Northport Dr.  
 Contractor  
West Sacramento, CA  
 Nevada contractor's license number  
 issued by the State Contractor's Board 0034680  
 Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller DEW-2361  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 7/21/2008

LOG# 109830

pg 2 of 2

THIS BORING LOG IS FOR VIKING'S INTERNAL PURPOSES ONLY. IT DOES NOT REPRESENT INFORMATION PROVIDED BY A SOILS ENGINEER.

LOG FOR BORING NO. #142		JOB NAME: K.G. WALTERS			
DATE STARTED 6/24/08	DATE COMPLETED 6/24/08	LOGGED BY EB	DRILLED BY EB	TYPE OF DRILL RIG #31	JOB NO. 5918
DEPTH OF HOLE 30'	DIAMETER OF HOLE 24"	CASING 8"	PERFORATIONS 20'	SAMPLING METHOD	ELEVATION

LOCATION  
N 38 57.847 W 119 46.845

DRILLERS NOTES:

DEW-75

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
			CLAY
			SILTY SAND
10'			SAND & GRAVEL
20'			MED TO COARSE SAND
30'			
40'			
50'			
60'			
70'			
80'			
90'			
100'			

STATE ENGINEER'S OFFICE  
24 JUN 2008 11:24 AM