

MW-10

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 109841
Permit No. 666
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65400

1 OWNER BARRIK TRSV ADDRESS AT WELL LOCATION HC 66 BOX 220
MAILING ADDRESS HC 66 BOX 220 28 MI. NE OF GOLCONDA NV 89414
GOLCONDA NV 89414 Subdivision Name County HUMDOIT
2 LOCATION SE 1/4 NE 1/4 Sec 34 T 39 S R 42 E Latitude N 41° 13' 3.53" UTM E NAD 27
PERMIT/WAIVER No. Longitude W 117° 13' 26.47" N NAD 83 NGS 84
Issued by Water Resources Parcel No. 41.2 (76470N; 117.2290190W NAD 27 (T))

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? Is there an existing well log?
 Domestic Irrigation Test Yes No
 Municipal/Industrial Monitor Stock No
If yes, what is replacement well NOI? 33269 If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 330 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why:

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	PVC	SCH 40	0	330

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used:

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
	UNKNOWN			

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL
Static water level DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

8 WELL PLUGGING MATERIALS

6 Additional Notes or Comments
TAG DEPTH OF WELL AT 330 FT. UNABLE TO Pull
PVC CASING. INSTALL TREMI PIPE. WELL WAS DRY.
Pump BENTONITE GROUT FROM BOTTOM TO 20'. CEMENT TOP 20 FT. BROKE PVC CASING OFF 2 FT BELOW GROUND SURFACE - REMOVE 5 FT STEEL CASING. BACKFILL TOP 1 FT WITH DIRT.

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
20	feet to	330	BENTONITE GROUT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
0	feet to	20	CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>

Neat Cement Fluid Weight lbs/gal
Bentonite Grout 12.5 % bentonite
Date Started 11-16-09
Date Completed 11-16-09

DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name LAYNE CHRISTENSEN Co. Contractor
Address 12030 E. RIGGS RD. CHANDLER, AZ 85249
Nevada contractor's license number 43608 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2215
Signed [Signature] By driller performing actual drilling on site or contractor
Date 12/30/09