

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin **105**

NOTICE OF INTENT NO. **58574**

1. OWNER **Gary Minter** ADDRESS AT WELL LOCATION **2309 Fremont Street, Minden, NV**  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION **SE 1/4 NW 1/4 Sec. 11 T. 13 N. R. 20 E. Douglas County**  
 PERMIT NO. **1320-11-001-008** Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  
 Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Municipal/Industrial  
 Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL		110	125	15
FRACTURED ROCK		125	135	10
BROWN CLAY-DG		135	142	7
DG GRAVEL		142	200	58
39.09593°N				
119.79157°W				
39.005905°N				
119.708333°W				
NAD 83				

8. WELL CONSTRUCTION  
 Depth Drilled **200** Feet Depth Cased **200** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **7 7/8** Inches To **110** Feet **200** Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>13</b>	<b>.188</b>	<b>100</b>	<b>200</b>

Perforations:  
 Type perforation **Factory milled**  
 Size perforation **3/32" x 3"**  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From **160** feet to **200** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal **160**  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From **160** feet to **200** feet

9. WATER LEVEL  
 Static water level **31** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature **COLD** °F Quality **CLEAR**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **BLAIN DRILLING & PUMP CO. INC.**  
 Address **P.O. Box 1255 Carson City, NV 89702**

Nevada contractor's license number issued by the State Contractor's Board **46498**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2167**  
 Signed **Jack Dotson** By driller performing actual drilling on site or contractor  
 Date **21 July 07**

Date started **19 July**, 20 **07**  
 Date completed **20 July**, 20 **07**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>10-13</b>		<b>3.0</b>

RECEIVED  
 2007 SEP 14 AM 10:46  
 STATE ENGINEERS OFFICE