WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109879
Permit No.
Basin 1064

NOTICE OF INTENT NO. 57771

1. OWNER David ITZA
MAILING ADDRESS P.O. Box 578 Battle MTN 89820
ADDRESS AT WELL LOCATION 360 Dillion CT.

2. LOCATION SE ¼ SW ¼ Sec. 24 T. 32 N/S R. 44 E. Lander County
PERMIT NO. Issued by Water Resources 011-050-30 Parcel No. D.S.F. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Sand + Gravel		10	20	10
Tan Clay		20	30	10
Blue Clay		30	75	45
Tan Clay		75	100	25
Sand + Gravel		100	110	110
Tan Clay		110	120	10

Latitude ____ UTM E 11 502 746 ☒ NAD 27
Longitude ____ N 4497073 ☐ NAD 83/WGS 84

40.626386°N
116.967533°W
NAD 27 (N)

Date started 7-19, 2006
Date complated 7-20, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	UNK	1½

2007 MAR 14 AM 10:56

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	71	120

Perforations:
Type perforation Sawed
Size perforation 3/16 X 3
From 90 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
(60-70' = Hole plug)
Gravel Packed: ☒ Yes ☐ No
From 70 feet to 120 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name L B J. Drilling Co. Contractor
Address P.O. Box 902 89446 Contractor

Nevada contractor's license number issued by the State Contractor's Board 9605
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed [signature] By driller performing actual drilling on site or contractor
Date 7-23-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627