

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60772

1. OWNER Mrs. Yvonne Hodges Hiller ADDRESS AT WELL LOCATION 5500 SCHURZ FALLON, NV
 MAILING ADDRESS _____
 2. LOCATION 1/4 NW 1/4 SE 1/4 Sec 29 T 19 N R 24 E Charleston County
 PERMIT NO. 006-511-04 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND-CLAY		0	19	19
BROWN CLAY		19	42	23
BLACK SILT + CLAY	X	42	128	86
BROWN SAND + CLAY + GRAVEL	X	128	142	14
BLACK SILT	X	142	145	3

39. 40833° N
 118. 78.334° W
 NAD 83

RECEIVED
 2008 OCT 24 PM 3:55
 STATE ENGINEERS OFFICE

N 39.408412° (12)
 W 118.786355 NAD 83

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 145 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	71	15
6 5/8	4	SDR 21	15	145

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 125 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 103 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No (103' - 105' = hole plug)
 From 105 feet to 145 feet

9. WATER LEVEL
 Static water level 23 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

Date started 29 Sept, 2008
 Date completed 30 Sept, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 4 Oct 08