

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY 109894

Log No. _____
Permit No. _____
Basin 090

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65170

1. OWNER Washoe County School District
MAILING ADDRESS 7495 S. Virginia Street

ADDRESS AT WELL LOCATION Facility ID #D-000728
931 Southwood Blvd. Incline Village, NV

Subdivision Name: _____ County: Washoe

2. LOCATION SW 1/4 SW 1/4 Sec 15 T 16N N/S R 18 E
PERMIT/WAIVER No. 127-030-16

Latitude 39°14'49.46"N UTM E NAD 27
Longitude 119°56'47.40"W N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Loose Sand		0	12	12
Clay with Sand		12	18	6
Sandy Clay, Brown		18	22	4
Clay with Some Sand, Brown		22	29	7
Sand Clay, Brown		29	35	6
Clay, Dark Brown		35	40	5
<p><u>39.247165°N</u> <u>119.945478°W</u> <u>N2032</u> <u>2010 JAN 11 09:12:33</u></p>				

WELL CONSTRUCTION				
Depth Drilled	40	Feet	Depth Cased	40
HOLE DIAMETER (BIT SIZE)				
From	To	From	To	
6	Inches	0	Feet	40
	Inches		Feet	
	Inches		Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/FT. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	8

Perforations:				
Type of perforation	Slot	From	To	
Size of perforation	.020	8	feet to	38
			feet to	
			feet to	
			feet to	

Annular Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
<input type="checkbox"/> Neat Cement	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	0	to 5	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8	to 40	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	#3 Sand			
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5	to 8	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
Type:	Medium			

Date started: 3-Jan, 20 10
Date completed: 3-Jan, 20 10

7. Water Level
Static water level: 27 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA			
TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P.
Contractor
Address 3632 Omec Circle
Contractor
Rancho Cordova, CA 95742
Nevada contractor's license number
issued by the State Contractor's Board C23-0073966
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M-1977
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 5-Jan-10