WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109943
Permit No.
Basin 087

NOTICE OF INTENT NO. 37827

1. OWNER: CONSULTANT Camp Dresser & McKee Inc.
MAILING ADDRESS: 7025 Longley Lane Suite #20, Reno, NV 89511
CLIENT: ADDRESS AT WELL LOCATION: Vista Canyon Group/ Sparks Solvent Fuel Site

2. LOCATION: NE ¼ NE ¼ Sec. 9 T. 19N N/S R. 20 E. Washoe County
PERMIT NO. Well #MW-230 (Issued by Water Resources) | 034-102-14 (Parcel No.) | Sparks (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand & gravel, some cobbles & boulders, dry, medium dense		0	2	2
Brown gray clay, some sand, moist, soft. Trace of gravel below 6 ft.		2	9	7
Gray brown sand, trace silt & gravel, moist, medium dense, wet below 10 ft.		9	11	2
Gray brown sand & gravel some cobbles, trace silt, wet meduim dense, slow drilling below 15ft.		11	19	8
Gray brown gravel & sand, trace cobbles & silt, wet, medium dense.		19	31	12
Gray brown sand, some silt, trace gravel, wet, medium dense.		31	36	5
Gray brown gravel & sand, trace silt, wet, medium dense.		36	40	4

Date started June 2, 1998
Date completed June 2, 1998

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 37 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	sch 40	0	37
4" locking cap, 12" flush mounted manhole				
4" bottom cap				

Perforations:
Type perforation: Factory sawed slot
Size perforation: 0.060
From 7 feet to 37 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 1-3ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Bentonite Seat at: 3-5ft.
Gravel Packed: [X] Yes [ ] No
From 5-40 feet to Coarse Aquarium feet

9. WATER LEVEL
Static water level 10 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date 6-25-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627