WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109945
Permit No.
Basin 087

NOTICE OF INTENT NO. 37117

CONSULTANT:
1. OWNER BROADBENT & ASSOCIATES, INC.
MAILING ADDRESS 1000 Bible Way, Suite 57
Reno, NV 89502

CLIENT:
ADDRESS AT WELL LOCATION
City of Reno
River front Block, SE corner Sierra & 1st St.

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 19N N/S R. 19 E. Washoe County

PERMIT NO. MW-1 (Issued by Water Resources) | 011-115-02&03 (Parcel No.) | Reno (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well graded sand, some fine, some gravel with boulders and cobbles.		0	14	14
Poorly graded fine to medium sand with little 1/2" gravel.		14	17	3
Poorly graded medium sand with little 1/2" gravel.		17	24	6

Date started 10-23-97, 20
Date completed 10-23-97, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
4 Inches	0 Feet	24 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" O.D.	SCH 40	PVC	0	10
Locking cap and surface completion 8" flush				
End cap				

Perforations:
Type perforation Factory sawed slot
Size perforation 0.020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 6'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal At: 6-8'
Gravel Packed: ☒ Yes ☐ No
From Sand #3 8-24' feet to feet

9. WATER LEVEL
Static water level 10.4 feet below land surface
Artesian flow G.P.M. N/A P.S.I.
Water temperature °F Quality not known

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date January 9, 2003

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627