

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Page 3 of 3 pages
 NOTICE OF INTENT NO. **50430**

1. OWNER THE BOEING COMPANY ADDRESS AT WELL LOCATION Rocketdyne, NV Filed
 MAILING ADDRESS 6633 Canoga Avenue D-393 T-487 Laboratory, Washoe County, Nevada
Canoga Park, CA 91303 2600 Whiskey Springs Road, Reno, NV 89510

2. LOCATION NE 1/4 SW 1/4 Sec. 7 T. 22N N/S R. 22 E Washoe County
 PERMIT NO. 77-320-09C R-422-B, 077-320-09 Area D Palomino Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Continued from page 2 of 3 pages				
fracture at 291 ft. borehole making 60GPM at 300 ft.	X	285	298	13
TUFF olive, moderately welded, very small phenocrysts fracture at 301 ft		298	305	7
TUFF red and olive, welded sparse, very small biotite phenocrysts		305	325	20

8. WELL CONSTRUCTION
 Depth Drilled 325 Feet Depth Cased 325 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
11.5	0	88	Feet
8 5/8	88	325	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8" steel		.188	0	325
6 5/8" drive shoe	Locking steel monument			

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3" slots
 From 260 feet to 320 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 98 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No SRI #8 sand
 From 98 feet to 325 feet

9. WATER LEVEL
 Static water level 43.2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not known

Date started November 13, 2002, 20
 Date completed November 18, 2002, 20

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
at 250 ft	6.5		
at 274 ft	30		
at 300 ft	60		

Information received 12-5=06

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller

Signed Jay C. Hadman
 By driller performing actual drilling on site or contractor

Date December 5, 2006