WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 109953
Permit No.
Basin 087

NOTICE OF INTENT NO. 33922

1. OWNER Consultant: CDM Engineers & Constructors Inc
MAILING ADDRESS 50 West Liberty, Suite 770
REno, Nevada 89501

Client:
ADDRESS AT WELL LOCATION Santa Fe Pacific Pipelin
P.O. Box 837
Rocklin, California 95677

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 19N N/S R. 20 E. Washoe County
PERMIT NO. BIO WellW1,W2,W3 (Issued by Water Resources) | 032-022-51 (Parcel No.) | 255 S. Stanford Way, Sparks, NV (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray-black fill rock				
brown sand & gravel		0	7	7
Gray silty clay		7	9	2
Sand & gravel with				
cemented gray streaks		9	27	8
Brown sand and gravel		27	38.9	11.9

Date started 4-16-97, 19
Date completed 4-17-97, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

8. WELL CONSTRUCTION W1 / W2 / W3
Depth Drilled 38.9 Feet Depth Cased 21.3/29.4/38.3

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	38.9 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
W1 2"	PVC	sch 40	+1.5	18
W2 2"	PVC	sch 40	+2	26
W3 2"	PVC	sch 40	+2	35

End cap, locking cap, surface completion

Perforations:
Type perforation Factory sawed slot
Size perforation 0.060
From W1 18 feet to 21 feet
From W2 26 feet to 29 feet
From W3 35 feet to 38 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal W1, W2, W3 12.9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite seal: W1 12.9-15/W2 23-24.1/W3 31.7-32.9
Gravel Packed: ☒ Yes ☐ No Lonestar
From W1 15-23 /W2 24.1-31.7/ W3 32.9-38.9 feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 0022549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed (By driller performing actual drilling on site or contractor)
Date June 26, 1998

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627